

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

Page 1 of 1

**LISTING No.** 3175-1539:0119

**CATEGORY:** Air Filter Units

**LISTEE:** FILTRATION GROUP, INC., 912 E. WASHINGTON ST, JOLIET, IL 60433  
Contact: Shelby Calvert (815) 774-1289 Fax (815) 726-8912  
Email: scalvert@filtrationgroup.com

**DESIGN:** Model Cleanroom Filter air filter units. The media is formed into pleat packs, with maximum thickness of 2.5 in. and separated with cotton thread or maximum thickness of 10 in. and separated with hot melt adhesive. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Class 1 and 2  
Maximum Depth: 10"

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, size, direction of airflow and UL label.

**APPROVAL:** Listed as Class I and II air filter units.

06-07-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **June 09, 2010**

Listing Expires **June 30, 2010**

Authorized By: **FRANCIS MATEO**, Program Coordinator  
Fire Engineering Division